

TIDLE PARK COIMBATORE LTD.

PRE-BID CLARIFICATIONS OF TENDER FOR OPERATION AND NON COMPREHENSIVE MAINTENANCE OF FIRE PROTECTION SYSTEM WORKS HELD ON 17TH SEPTEMBER 2026 AT 12.00 NOON IN THE MEETING ROOM OF TIDEL PARK COIMBATORE LTD. (TPCL), COIMBATORE.

Tender No. D-MECH-12013/1/2026

Sl. No.	Page No. / Clause No.	Clarification Sought	Response Made
1.	Page 49 / Clause 6(2) of Vol.I	Maintenance of real hose, fire hydrant valve etc. not covered in the scope?	Maintenance of real hose, fire hydrant valve, etc. are covered under periodic maintenance schedule
2.	BOQ / Clause 2.01	Should we include the cost of valves, hose and other accessories in the quote for refilling of fire extinguishers?	Yes. Quote should be inclusive of all accessories required for refiling and pressure testing of fire extinguishers.
3.	Pg. No.51 / Clause 21 & 22 of Vol.I	Spares and consumables required for operation & maintenance of diesel engine pumps be provided by contractor or TPCL?	Necessary spares and consumables required for operation and maintenance of FPS Works and diesel engine pumps will be provided by TPCL. Necessary tools, tackles, measuring equipments etc., required for maintenance are under the scope of the contractor.
4.	Pg.51 / Clause 26 of Vol.I	Is fee for renewal of fire license is under contractor's scope?	No. Contractor should only co-ordinate with TPCL during fire audit by TN Fire Service.

Note: Details shall be uploaded along with tender document in the e-tender online, which submission alone will be considered for evaluation. Submission of any details in any other manner will not be entertained.